

East Bayshore Recycled Water Project Water Quality Improvements Pilot Study

BACWA Recycled Water Committee
May 17, 2022

Agenda



- East Bayshore Recycled Water Program
- Water Quality Challenges
- Water Quality Improvements Pilot Study
- Q&A


EBMUD Recycled Water Overview



- Recycled water use: 1970
- North Richmond: refinery
- San Leandro: golf courses
- San Ramon: residential and golf courses
- East Bayshore: landscape & industrial



East Bayshore Recycled Water Treatment



East Bayshore Service Area

- Online since 2008
- Goal = 2.3 mgd by 2040
- Current demand = 0.3 mgd
- 42 landscape customers
- Transmission ($>12''$) = 3.4 miles
- Distribution ($4'' - 12''$) = 5 miles
- Average TDS = 900 mg/L
- Average Ammonia = 40 mg-N/L
- Drought TDS = 1100 mg/L
- Drought Ammonia = 60 mg-N/L



Challenges



- Infrastructures
- Water quality

Challenges: Infrastructures





- Low demand users
- Development changes
- Cost/benefit ratio too low

Challenges: Water quality





- Perception
- Water quality
 - High TDS and ammonia prohibit cooling tower & industrial uses
 - High TDS during droughts potentially damage landscaping

Challenges: Water quality



Challenges: Water quality



Challenges: Water quality



Solutions




- **Challenge:** Existing water quality
- **Solution:** Conduct water quality improvements pilot study to produce high quality recycled water that is suitable for cooling tower uses and during droughts
- 3-year Water Quality Improvements Pilot Study
- **Pilot Study components:**
 - Partial RO to reduce TDS during droughts
 - Full RO/Breakpoint chlorination to supply cooling towers
 - Alternative cooling tower point-of-use treatment
 - Alternative raw wastewater sources with reduced TDS


Test site



Equipment




Equipment



RO Unit




Equipment



Task I – Partial RO


Objective: blending to maintain TDS ≈ 500 mg/L



Status:

- Started testing April 2021
- Completed Phase 1 testing March 2022
- Complete January 2024

Water quality parameters



Parameter (units)	Planning Study (2011-2016)		Pilot RO Feed (2021)	
	Average	90 th Percentile	Average	90 th Percentile
Chloride (mg/L)	322	480	315	390
Total Dissolved Solids (mg/L)	856	1,200	900	1,100

Operations

Balancing act

Parameter	Capital	O&M
↑Recovery	↓	↑
↑Flux	↓	↑
↑Acid	↑	↑↓
↑Reductant	↑	↑↓
↑CIPs	↓	↑↓

Preliminary results



Preliminary results



RARE
2.0 mgd
10 gfd flux

Task II – Full RO & breakpoint chlorination

Centralized treatment



Objective: removing ammonia for cooling tower uses




Status:

- Selected breakpoint chlorination November 2020
- Start testing July 2022
- Complete January 2024

Task III – Point-of-use Treatment

Objective: treatment at customer sites




Status:

- Selected test site March 2021
- Start testing August 2022
- Complete January 2024

Task IV – Alternative supply assessment

Objective: assessing alternative supply sources



Status:

- Started sampling April 2021
- Completed sampling March 2022
- Evaluating options

Questions/Comments

