



Chandler Branch
6750 W. Boston St. Chandler, AZ 85226
(480) 961-4189 Fax (480) 961-4644

CERTIFICATE OF ANALYSIS

Product Citric Acid 50% Solution
Part No. 492389, 585892, 979227, 708534
Lot No. CH-641146
Date 02/22/2024

	Limits	Results
Acidity as Citric Acid, wt. %	48.0 min.	50.86
Density at 20C, g/ml	1.230 min.	1.248
Specific Gravity 20/20C	1.232 min.	1.251
Refractive Solids, Brix %	40.6 min.	43.2
Appearance	Clear; Colorless to Pale Yellow	Pass



Certified to NSF/ANSI Standard 60
Maximum Use for Potable Water is NA mg/L
Product Function: Membrane Cleaner

This product, as a Membrane Cleaner, is designed to be used off-line and flushed out prior to using the system for drinking water, in the membrane manufacturer's use instructions.
The pH of the influent and effluent water should be monitored to ensure that all traces of the product have been removed before placing into service.

Certification to NSF/ANSI Standard 60 applies only if product has been packaged by or shipped in bulk directly from Brenntag Pacific, Inc. in Chandler, Arizona.

David Payne
Technical Services

VND: 100688