



**BACWA Nutrient Infoshare 1  
Adventures in Optimization  
@ the San Jose / Santa Clara  
Regional Wastewater Facility (RWF)**

*June 1<sup>st</sup> 2026*



**San José-  
Santa Clara  
Regional  
Wastewater  
Facility**

# The Lower South San Francisco Bay

Dumbarton Bridge

Palo Alto  
229K


Coyote Creek

San Jose  
1.4 M

Sunnyvale  
154K

Three wastewater treatment plants discharge to the lower South San Francisco Bay

# San Jose – Santa Clara Regional Wastewater Facility




- Second-largest advanced wastewater treatment facility on the West Coast
  - 167 MGD capacity
  - ~2,600-acre site
  - ~ 210 acres inside the fence line, including new process areas
- Serves
  - ~1.4 million people
  - ~17,000 businesses
  - 8 cities & County areas
  - More than 2300 miles of collection system with 27 lift stations

Delivering world-class utility services and programs to improve our health, environment, and economy.




# South San Francisco Bay



San José-Santa Clara  
Regional  
Wastewater  
Facility

**Where the Treated wastewater goes...**



# San José-Santa Clara Regional Wastewater Facility


1956-57	Then	Now
<b>Service Population</b>	380,000	1,430,000
<b>BOD (Kg/d)</b>	47,000	1,300
<b>TSS (Kg/d)</b>	25,000	600
<b>Dissolved Oxygen (ppm)</b>	< 1.0	> 6.2
<b>Ammonia (ppm)</b>	> 60	< 2.0



# Wastewater Treatment Eras

- **1957-1964:** primary treatment – ~ 50% BOD reduction
- **1964-1979:** secondary treatment - >90% BOD reduction
- **1979-1997:** tertiary/advanced treatment - >90% BOD reduction and >80% nutrient reduction
- **1997-NOW:** Biological Nutrient Removal (BNR) - >90% BOD reduction and >80% nutrient reduction AND energy savings by combining two biological systems into one

1956



1964





1979



1997




# Simplified Process Flow Diagram





Revised: May 20, 2025

# BNR at the RWF – A Closer Look




- Schematic views of the RWF's parallel BNR treatment processes.
- Primary Effluent Flow is typically split between the two, with BNR-1 @ ~60% and BNR-2 @ ~40%.




# Aeration Tank Systems for both BNR-1 and BNR-2




## BNR-1



## BNR-2




# BNR Effluent Quality vs kg/day TIN




- Ammonia  $\text{NH}_3\text{-N}$  =  $<0.2$  – typically  **$<0.1$**
- Complete nitrification
- Nitrite,  $\text{NO}_2$  =  $<0.2$  – typically  **$<0.1$**
- **Nitrate,  $\text{NO}_3$   $<14.0$  – typically  $<12.0$**
- **$[\text{Q} (110) \times \text{conc} (12.0) \times 8.34]/2.2=5004\text{kg/day}$**
- Current interim limit = 6400, ok for now
- The RWF adds a few parts of ammonia for *Chloramination* during disinfection
- **Final limit\* is 5000 kg/day, and the RWF will not be able to meet the final limit under the current configuration.**

# What the RWF has done in recent memory



- Take a look at the process air supply to all 4 quads. The RWF uses air to mix instead of mechanical mixers...
- Energy is at a premium, and in the late 2000s, the DOE was offering grants to come up with ways to save energy... So...
- Pulse air was applied in the anoxic and anaerobic zones where only enough air at specific intervals (on-3mins/off-5) was/is added to keep flocs in suspension.
- Settling rates were analyzed to ensure sludge did not accumulate in these zones.
- What could go wrong?
- **Is it worth it? We do not have a permit limit for phosphorus**

# What the RWF has done in recent memory



- The RWF has very long mixed liquor channels that convey process to the clarifiers in each BNR system.
- These channels are also mixed using coarse bubble diffusers.
- Air has been decreased to reduce some nitrate with modest success.
- Unintended consequences for energy/nutrient optimization...
- Phosphate, PO<sub>4</sub>, has been a challenge due to the size of the anoxic/anaerobic zones.
- These zones are 50% of the overall treatment train capacity...
- Struvite has been a challenge since the conversion to BNR and even more so when efforts to remove more nitrogen have been implemented...


# Only so much we can do...for now



- The RWF has adjusted DO targets, both lowering setpoints and changes to the levels in specific oxic zones.
- The RWF has adjusted mixed liquor channel air flows
- The most significant impacts have been the move from static air mixing (air supplied all the time to anoxic and anaerobic zones) to pulse air mixing.
- The unintended consequences have hit the RWF hard. Struvite is now a greater challenge due to the maximum phosphorus uptake resulting from these changes and the size of the anoxic and anaerobic zones.
- More tests to come, AND ABMP


# Existing and Future Secondary Treatment Process Schematic

Existing



Future

Process modifications in red are required to meet the new nutrient watershed permit.



# Use the resources – Thanks BACWA



[HOME](#) [ABOUT](#) [MEETINGS](#) [BACWA COMMITTEES](#) [EDUCATION](#) [BACWA MEMBERS](#) [NUTRIENTS](#) [CONTACT US](#)

## – DR. DAVID JENKINS TECHNICAL SERIES NUTRIENT SEMINAR –

### NUTRIENT REMOVAL IN BAY AREA WATER RECLAMATION FACILITIES

#### DR. DAVID JENKINS TECHNICAL SERIES



#### PRESENTATIONS

[Workshop Booklet & Agenda](#)

- 1 – Introductory and Concluding Remarks
- 2 – San Francisco Bay Nutrient Watershed Permit
- 3 – Developing a Nutrient Management Strategy or Roadmap
- 4 – Nitrogen Removal Fundamentals
- 5 – Split Treatment Nutrient Reduction at Sunnyvale
- 6 – USD Enhanced Treatment and Site Upgrade Program (ETSU) Program
- 7 – Hayward Water Pollution Control Facility Upgrades
- 8 – MABR design at Windsor WRF, CA
- 9 – Palo Alto Regional Water Quality Control Plant Secondary Treatment Upgrades
- 10 – Wastewater Intensification at a Large Municipal Airport
- 11 – DEMON Sidestream Treatment at Sunnyvale



OR...





San José-Santa Clara  
Regional Wastewater Facility

